

Sprinkler Variance Committee 10/9/2020

Agenda

Join Zoom Meeting

<https://zoom.us/j/91931621386?pwd=aTVuUnV4K0xvdVpWMUliWGptMmlqdz09>

Meeting ID: 919 3162 1386

Passcode: 433869

Good Samaritan Haven Overflow Shelter 64 State St

- Change in occupancy classification requires sprinkler
- The facility will be monitored by a full time staff member who will be awake at all times. This person will serve as a fire watch.
- Both floors have two means of egress, with one egress from each floor leading directly outdoors.
- A wireless interconnected smoke and carbon monoxide alarm system will be installed to provide early notification of fires or elevated CO levels.
- The occupancy load will be relatively low.
- Exit markings will be enhanced.